



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	8160-2064:0026
<b>CATEGORY:</b>	8160 - UNDER EAVE FOR WILDLAND URBAN INTERFACE (W.U.I)
<b>LISTEE:</b>	Nusku Partners LLC 4501 Brickell Privado Street, Ontario, CA, 91761 Contact: Hummel, Tim (909) 591-4841 (909) 591-4818 Email: tim@wehardenhomes.com
<b>DESIGN:</b>	"Nusku Fireblocker" Clear Fire Retardant Fingerjoint Redwood ceiling cladding products to include Tongue & Groove and Shiplap minimum dimension 1x4 (nominal) installed over standard 7/16" oriented strand board (OSB), plywood or gypsum. Refer to manufacturer's installation instructions and product data sheet.
<b>RATING:</b>	
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee name. Model number, rating and SFM label.
<b>APPROVAL:</b>	Listed as under eave materials for use in the Wildland Urban Interface areas. Refer to manufacturer's Installation Manual for details.
<b>NOTES:</b>	Test Protocol SFM 12-7A-3

10-22-15 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 04/04/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Damon Lam**, Program Coordinator  
Fire Engineering & Investigations Division